

## The Metropolitan Government of Nashville and Davidson County....

## Board of Gas/Mechanical Examiners and Appeals Agenda Minutes

Meeting Date:

Tuesday - April 17, 2018

Place: Metro Office Building

Davidson Room - 800 2<sup>nd</sup> Avenue, South - Second Floor

Time: 1:30 P.M.

BOARD MEMBERS	TERM EXPIRES	ATTENDANCE	OTHERS PRESENT
Michael Porter, Chairman Jeff Zimmerle, Vice Chairman Milton Henderson Harold Ferguson Lynn Taylor Mark T. Bandy Fil Harris	January 20, 2018 August 21, 2018 August 21, 2019 August 21, 2016 August 21, 2016 August 21, 2018 June 20, 2021		

## AGENDA TOPICS

- I. Approval of Last Month's Minutes and Call Meeting To Order
- II. Appeal Cases
- III. Appearing Before The Board
- IV. Other Business
- V. Consent Agenda
- VI. Adjournment

## APPPEAL OF DECISIONS FROM THE BOARD OF GAS/MECHANICAL EXAMINERS AND APPEALS

Pursuant to the provisions of § 2.68.030 of the Metropolitan Code of Laws, please take notice that decisions of the Metropolitan Board of Gas/Mechanical Examiners and Appeals may be appealed to the Chancery Court or Circuit Court of Davidson County for review under a common law writ of certiorari. Any appeal must be filed within sixty (60) days after entry of a final decision by the Board. Any person or other entity considering an appeal should consult with an attorney to ensure that time and procedural requirements are met.

I. APPROVAL OF MINUTES AND CALL THE MEETING TO ORDER: Approval of the April 18, 2017 Minutes	Motion: First: Second:
Changes:	Opposed:
Approval By: Signature of Chairman:	

II. APPEAL CASES					
II. APPEAL CASES					
Appeal Case No. 20180017681					
Site Address: 209 10 <sup>th</sup> Avenue, South Map/Parcel Number: 09309032000 Appellant: Smith Gee Studio OWNER: Cummins Station LLC	/Parcel Number: 09309032000 ellant: Smith Gee Studio				
<u>Code Provision:</u> The 2012 IECC section C-403.3.1 Economizers states that each cooling system that has a fan shall include either an air or water economizer meeting the requirements of Sections C403.3.1.1 through C403.3.1.1.4.					
<u>Variance Requested</u> : Due to historical concerns and documentation from the mechanical engineer, the building owner requests waiving the requirement for economizers on HVAC systems for all tenants.					
NOTES: Request is for the entire Building – for each tenant space – regarding mechanical equipment which is required and it is seen on the outside of the building.	Motion: First: Second:	Opposed or Abstained:			
Appeal Case No. 20180018969					
Site Address: 813 Gallatin Avenue Represented by: Melissa Bednarik Map/Parcel Number: 09305018200 Appellant: Melissa Bednarik OWNER: Brian Jernigan					
<u>Code Provision:</u> The IMC 403.3 Outdoor airflow rate. Ventilation systems shall be designed to have the capacity to supply the minimum outdoor airflow rate determined in accordance with this section. The occupant load utilized for design of the ventilation system shall not be less than the number determined from the estimated maximum occupant load rate identified in Table 403.3. For Nail salons, footnote b to table 403.3 requires mechanical exhaust and prohibits the recirculation of air. Footnote h requires each nail station to be provided with a source capture system capable of exhausting not less than 50 cfm per station.					
<u>Variance Requested</u> : Appellant appeals the requirement for a source capture exhaust system at each nail station.					
NOTES: Renovations to 2200 SF shell space for a Business occupancy for Cured Nails, a nail salon per Permit # 2017067519.	Motion: First: Second:	Opposed or Abstained:			

Appeal Case No. 20180019181  Site Address: 4000 Hillsboro Pike Map/Parcel Number: 11714017600 Appellant: Nathan J, Pies OWNER: Green Hills Mixed Use, LLC	Represented by:	Nathan J. Pies			
Code Provision: 2012 IMC - Section 506.1 require grease hood duct systems shall comply with NFPA 96 - 2012 Edition.  Variance Requested: Allow the grease duct located on the exterior of the building to slope to the utility fans. Owner will install grease guard around fans to help with grease. The grease duct located in the space slopes back to the hood and is collected at the hood.					
NOTES: Tenant build out of 6,469sf shell space for Tru Kitchen.	rue Food Motion:  First: Second:	Opposed or Abstained:			
III. APPEARING BEFORE THE BOARD					
No Business					
IV. OTHER BUSINESS					
ELECTION OF OFFICERS:					
Nominations for Vice Chairman:		2 <sup>nd</sup>			
Nominations for Vice Chairman: 1 <sup>t</sup> 2 <sup>nd</sup>					
V. CONSENT AGENDA					
No Business					
VI. MOTION FOR ADJOURNMENT:	Motion: First: Second:	Opposed or Abstained:			